

# Altronic, Inc.

## Service Bulletin

Date: 2-4-05

Subject: GTI DE-1510 and DE-2510 Improvements

In November 2004 there was a running change made to the DE-1510/2510 to allow for ongoing improvements to the product line. Starting with Serial Number 1120 of both the Display Module and the Terminal Module, these units will be referred to as V2.0, and will have the following improvements:

- Ease of Initial Configuration - The system will now be initially configured via an improved and user friendly Terminal Program
- Transducer calibration has been added to the keypad (needed a PC and Terminal Program on earlier version )
- Added English/Metric keypad selection/conversion
- Added a programmable time delay (keypad accessible) for vibration sensors
- Improved Calibration menu in the Terminal Program
- New Terminal Program V2.0 (CD contains earlier V1.1 as well as V2.0)

Updates to V2.0 will require the replacement of the Terminal Module (691142-2) as well as the Display Module.

Field replacement of either the Display Module or Terminal Module on vintage (V1.1) units will affect operation when replacing with newer "S/N 1120 and higher" modules. Conversion or replacement of either module will require the update of the "mate". Upgrades to V2.0 **WILL** require the unit to be reprogrammed using the new Terminal Program Software.